



## ZONEX SYSTEMS

### GEN II ZONING SYSTEM BUILD QUESTIONNAIRE and OUTLINE FOR CUSTOMERS

- **Number of rooftop units?** To determine how many **GEN II** control panels, **GCLK** time clocks, and **TR100** transformers.
- **Tonnage** - CFM (air delivery) for each unit?
- **Number of Zones?**
- **New installation or retrofit? Why?** To determine if **RZXIT** (zone stat and damper actuator) will be used
  - If retrofit, will contractor be using the existing dampers? If so, select **RZKIT**
- **If buying new dampers, need amount and sizes. Round or rectangular?** **STMPD** round, **STCD** rectangular
- **Are any dampers being slaved? How many?**
- **Are there existing VAV boxes on the job?**
- **Bypass Damper size?** **STBP** round, **STCDBP** rectangular. Need 40Va transformer.
- **Number of thermostats?** **EzTouch**. Zonex requires 1 thermostat per damper
- **Unshielded twisted pair cable for communication – TWPR**

### IMPORTANT ZONING SUPPORT INFORMATION

Technical Support - 1-800-228-2966

Website - [www.zonexproducts.com](http://www.zonexproducts.com)

Request for quote: [rfq@zonexproducts.com](mailto:rfq@zonexproducts.com)

Training webinar available for contractor. Schedule at this link:

[www.zonexproducts.com/us/webex](http://www.zonexproducts.com/us/webex)

Vince Racalbuto, National Sales Manager. E-mail: [vince@zonexsystems.com](mailto:vince@zonexsystems.com) Mobile: 760-546-8715