

**CITY OF IRONWOOD
PUBLIC SAFETY DEPARTMENT
FIRE INSPECTION REPORT**

Business Name:	Business Phone #:		
Address:	E-mail:		
Building Owner:	Contact Phone #:		
2. After-Hours Emergency Contact:	Contact Phone #:		
3. After-Hours Emergency Contact:	Contact Phone #:		
<u>Access and Premises:</u>	Yes	No	N/a
Are Address numbers for the building visible from the street?			
Is the exterior fire department access unobstructed?			
Does your building have a Knox Box? If so, will the keys inside it open all doors? If locks are changed contact City of Ironwood Public Safety Department to install new keys.			
Is combustible vegetation removed so as to not create a fire hazard?			
Is there maintained a minimum 3' clearance around fire hydrants?			
<u>Egress (Exiting)</u>			
Are the exit ways and doors easily recognizable, unobstructed, and maintained functional?			
If the main exit door is provided with key-locking hardware is there a sign above the door that states "THIS DOOR MUST REMAIN UNLOCKED WHEN BUILDING IS OCCUPIED" and are the other exit doors operable from the inside w/o the use of a key or any special knowledge or effort?			
Are the exits and exit enclosures free of storage?			
Are doors with self-closing hinges maintained in the closed position (not blocked open)?			
<u>Electrical</u>			
Are all electrical outlets, switches and junction boxes properly covered with cover plates? Is the electrical system safe from any apparent shock and/or other electrical hazards?			
Are circuit breakers/fuses labeled so as to identify the area protected?			
Is the area in front of the electrical panel(s) clear, by at least 30"?			
Are extension cords used only for temporary use? (90 DAYS)			
Are extension cord(s) of heavy duty construction, maintained in good condition, and only used as temporary wiring, or to service small portable appliances?			
Are extension cord(s) plugged directly into an approved receptacle, power tap or multi-plug adapter and, except for approved multi-plug extension cord(s), serve only one portable appliance?			
Is the capacity of the extension cord(s) greater than the rated capacity of the portable appliance supplied by the cord(s)?			
If multiple items need to be plugged in, is a power tap utilized with a built-in circuit breaker and is the power tap plugged directly into a permanently installed receptacle?			
<u>Emergency Lighting/ Egress Illumination</u>			
If emergency lighting is provided, is it maintained in operable condition?			
Is the means of egress illuminated when the building or structure is occupied?			
<u>Exit Signs</u>			

If exit signs are required, are they maintained as illuminated or self luminous?			
Does the backup-battery work? (push the test button, the exit sign should illuminate under battery power)			
<u>Fire Alarm System</u>			
If the building is equipped with a fire alarm system, has the required annual service of the fire alarm system been performed by a qualified fire alarm company?			
<u>Fire Safety and Evacuation Plans</u>			
If drills are required, are they conducted successfully at varying times and under varying conditions and are records maintained on the premises?			
If required, are evacuation plans posted?			
If required, do you have fire safety plans?			
<u>Fire Extinguishers</u>			
Is there access to a fire extinguisher(s) rated at a minimum of 2A-10BC per 6,000/ square ft? In low hazard areas and 3,000 sq. ft. in medium hazard areas?			
Is the travel distance from all portions of the building less than 75' to a fire extinguisher?			
Are all fire extinguishers visible and accessible (not blocked)?			
Have the fire extinguisher(s) been serviced/ tagged by a qualified technician within the last 12 months?			
Is the fire extinguisher(s) properly mounted? Proper locations-near exit doors where possible, not exceeding maximum travel distance, properly mounted (maximum 5' high if less than 40 lbs., maximum 3 1/2' high if greater than 40lbs. In all cases, minimum 4" above the ground)?			
<u>Fire/Smoke Separations</u>			
Are the fire/smoke separations (smoke doors, fire doors, walls, etc.) maintained in working condition?			
<u>Fire Suppression Systems</u>			
Is storage maintained a minimum of 18" below head deflectors in fire sprinklered areas?			
If the building is equipped with a fire sprinkler system, has the required annual service of the fire sprinkler system been performed in the last year by a qualified sprinkler company?			
In the commercial cooking applications, has the hood suppression system been serviced in the last six months and is the hood cleaned at intervals to prevent the accumulation of grease?			
<u>Heat producing appliances</u>			
If portable electric heaters are used, are they used safely? Are they plugged directly into wall outlets and kept a minimum of 3' away from combustibles.			
<u>House Keeping and Decoration</u>			
Is combustible rubbish that is stored in containers outside of vault storage rooms removed from the building a minimum of once each working day?			
Are oily rags or similar materials stored in metal, metal lined or other approved containers equipped with tight fitting covers?			
Are combustible decorations flame retardant?			
<u>Mechanical Hazards</u>			
Is the venting for exhaust products of combustion working properly for gas appliances? (i.e.: water heaters, furnaces, etc.)			
<u>Smoke Detectors</u>			

If smoke detection is required in common areas such as corridors or part of the fire alarm system, have they been tested in the last year by a qualified technician?			
<u>Storage of Combustibles</u>			
Is the storage of combustible material orderly and clear of exits and openings?			
Are Combustible materials not stored beneath the building or structure?			
Are the boiler rooms, mechanical rooms and electrical panel rooms maintained free of all combustible materials?			
Are rubbish containers over 5 1/3 cubic feet (40 gallons) provided with lids and made of noncombustible construction?			
Are dumpsters that are 1.5 cubic yards or more not stored inside the building and placed more than 5' from combustible walls, openings or combustible roof eave lines?			
If you have storage of compressed gas containers (such as Co2, helium, etc.) are they chained to prevent falling?			
<u>Storage of Combustible and Flammable Liquids</u>			
Are quantities in excess of 10 gallons of flammable and combustible liquids used for maintenance purposes and the operation of equipment stored in liquid storage cabinets?			

A "NO" response to any of these questions indicates the presence of a fire code violation. Once all hazards identified as having a "NO" response are corrected, please sign, date, and return this form to us. Thank you for your cooperation. Completion of this form does not eliminate all fire inspections conducted by the Ironwood Public Safety Department.

--	--	--

Print name of Responsible person:

Signature:

Date:

Notes and additional comments

If you have any questions feel free to contact the Ironwood Public Safety Department.

**Ironwood Public Safety Department
123 W. McLeod Avenue
Ironwood, MI 49938
Phone: 906-932-4808
Fax: 906-932-4808**